

***PROVIDE AND INSTALL A LOCK-OFF KIT ON THE CIRCUIT BREAKER AND MARK AS *EMERGENCY LIGHTING

* LARGEST MOTOR

** PROVIDE AND INSTALL A LOCK-OFF KIT ON THE CIRCUIT BREAKER

** PROVIDE AND INSTALL A LOCK-OFF KIT ON THE CIRCUIT BREAKER

* PROVIDE 6 FIBRE BREAKER

* LARGEST MOTOR

PANEL 'P2A'	=	136.5 A
PANEL 'P2B'	=	128.4 A
PANEL 'P2C'	=	69.9 A
PANEL 'P2D'	=	147.8 A
PANEL 'P2E'	=	82.2 A
HP-1	=	85.0 A
HP-2	=	85.0 A
TOTAL LOAD:		735 A